

荒川低地海成堆積物の地下水水質に原位置長期熱負荷が与える影響 Effects of in-situ, long-term thermal loading on groundwater quality in marine sediments of Arakawa Lowland, Japan

斎藤 健志^{1*}; 植木 崇¹; 濱本 昌一郎²; Moldrup Per³; 大久保 智司¹; 川本 健¹; 小松 登志子¹
SAITO, Takeshi^{1*}; UEKI, Takashi¹; HAMAMOTO, Shoichiro²; MOLDRUP, Per³; OHKUBO, Satoshi¹; KAWAMOTO,
Ken¹; KOMATSU, Toshiko¹

¹ 埼玉大学 / JST-CREST, ² 東京大学 / JST-CREST, ³ オルボー大学 / JST-CREST

¹Saitama University / CREST, JST, ²The University of Tokyo / CREST, JST, ³Aalborg University / CREST, JST

Subsurface temperature increase ("subsurface warming") has been documented below many large cities worldwide. The observed subsurface temperature increase has shown close relations with surface warming effects due to global warming and urbanization. Recently, ground source heat pump (GSHP) systems have become popular as a renewable energy technology for space cooling and heating. Operation of GSHP systems for space cooling discharges waste heat into the subsurface environment and, thus, induces additional subsurface temperature increase. However, any potentially negative impacts of GSHP-induced temperature increase on the subsurface environment have not been studied in detail. The objective of this study was therefore to investigate the effects of in-situ, long-term thermal loading on groundwater quality.

A GSHP system was installed in a 50-m deep borehole with a corresponding 50-m long U-tube heat exchanger at the campus of Saitama University in the Arakawa Lowland, Japan. Four groundwater monitoring wells were installed in a marine sand sediment aquifer (around 17-m depth) at 1-m (W1), 2-m (W2), 5-m (W5), and 10-m (W10) distance from the U-tube. At each monitoring well, temperature detectors were placed in 10 depths at approximately 5-m interval, and the subsurface temperature was monitored before and during thermal loading. For the thermal loading, approximately 40 °C water was circulated inside the U-tube heat exchanger for 13 months, and groundwater was frequently sampled from all four monitoring wells every 1 to 2 weeks. A wide spectrum of chemical properties (including pH, EC, DO, ORP "oxidation-reduction potential", dissolved gases, dissolved organic carbon, inorganic ions, and trace elements) were measured to characterize groundwater quality.

The subsurface temperature at the nearest monitoring well (W1) increased gradually with approximately 8 °C from 17 °C (baseline) to 25 °C during 13 months of thermal loading. In contrast, at the farthest monitoring well (W10), there was no significant change in subsurface temperature, and W10 was therefore selected as a reference (non-temperature affected) monitoring well. A number of chemical components in the groundwater, including boron and potassium, increased markedly at W1 compared to W10. Since marine sediments typically contain high concentrations of chemical components including boron and potassium, the observed increase in groundwater concentration is likely due to thermally-induced dissolution and/or desorption from the marine sediment. The possible mechanisms behind the observed concentration increases will be discussed.

Keywords: subsurface temperature, thermal pollution, long-term thermal loading, GSHP, marine sediment, groundwater quality